

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for City of Bellevue

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 3rd quarter of 2017 we did not monitor for Total Trihalomethanes (TTHM) and Total Haloacetic Acids (HAA5) and therefore cannot be sure of the quality of our drinking water during that time. However, we did resample during the 4th quarter of 2017. Once results are received from lab they will be posted.

| Results: | | Max Levels |
|-------------|-----------------------------|---|
| TTHM | (sample #1 0.82 ug/L | sample #2 5.53 ug/L) <i>MCL= 80 ug/L</i> |
| HAA5 | (sample #1 3.15 ug/L | sample #2 2.92 ug/L) <i>MCL=60 ug/L</i> |

Concentrations are well below (MCL) maximum contaminant levels

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What should I do?

There is nothing you need to do at this time.

What happened? What is being done?

E.g. We have since taken the required samples on 11/8/2017 and submitted to the lab.

For more information, please contact Richard Dyches at 352-266-0399 or 5343 SE Abshier Blvd, Bellevue, FL. 34420.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by City of Bellevue. State Water System ID#: **3420074**. Date distributed: 1/23/18